

SIMPLIFIED TEST CERTIFICATE

Nº. 15/11423-2493-S

Bellaterra, 10th December 2015	Product:
CEMENT DESIGN Av. Rio Guadalquivir 2 28906 Getafe (Madrid)	ECOCEMENT/CLASSIC /CONCRET/TRANSIT/RUSTIC + PU ANTISLIP CON ESFERAS DE VIDRIO
REQUESTED TEST	
Determination of Slip Resistance Value (USRV). UNE-ENV 12633:2003, Annex A.	
USRV Value: 47 Slip Resistance Rd: CLASS 3	

Responsible for Construction Mat.
LGAI TECHNOLOGICAL CENTER, S.A.

Technician responsible
LGAI TECHNOLOGICAL CENTER, S.A.

These results are exclusively related to the received material in Applus Laboratories and proved under given indications.

Applus+, guarantees that this work has been made in accordance with our Quality and Sustainability System, fulfilling the contractual conditions and legal norms.

Within our improvement program we would be grateful if you would send us any commentary that you consider oportune, to the person in charge who signs this document, or to the Quality Manager of Applus+, in the following e-mail address: satisfaccion.cliente@appluscorp.com